

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ
ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ ਬੁਢਲਾਡਾ
ਫੋਨ ਨੰਬਰ 01652-250042 ਈ-ਮੇਲ sdebudlada@gmail.com

No. 912

Date. 15/07/2025


To Whom it May Concern

SAFE DRINKING WATER CERTIFICATE

It is Certified that an inspection team headed by Sh. Harmanpreet singh Dandiwal Junior Engineer (name of officers with designation) From W/S & Sanitation S/d Budhlada (name of Depart/Office) took water sample from AKAL ACADEMY Uddat Saidewala (Budhlada) on 26.05.2025 as per the testing report submitted to this office, It is found that the AKAL ACADEMY Uddat Saidewala (Budhlada) has safe drinking water & sanitation facilities for the students and member of staff of the institutions.

This Safe Drinking Water & sanitation Certificate is valid up to.....14/07/2026


ਹਰਮਨਪ੍ਰੀਤ ਸਿੰਘ ਦੀਵੀਵਾਲ ਜੇ.ਈ.
ਉਪ ਮੰਡਲ ਜ/ਸ/ਸ ਬੁਢਲਾਡਾ

Signature With Seal: 
Name: E. Sh. Kachhpal Singh
Designation: Sub Divisional Engineer
Water Supply & Sanitation
Budhlada Division Engineer



TC-11388

TEST REPORT

Name & Address of Customer : E,DWSS,BUDHLADA AT MANSA E,DWSS,BUDHLADA AT MANSA		Customer Reference No.	No : 583 Dated : 26/05/2025
		Sample Submitted by	MR NIRMAL SINGH
		Date of Sample Receipt	28/05/2025
		Analysis Starting Date	28/05/2025
		Analysis completion Date	29/05/2025
Discipline : Chemical Testing		Group: Water	
SR No.:	TC11386250000058F	Sample Type :	Water
Test Report No.:	DWTL/MNS/2526/00061	Date of Issue :	29/05/2025
Registration no.:	DWTL/MNS/REG2526/00745	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Transparent Plastic Bottle
Theme/Source:	Saidewala(RO)	Location/Depth :	AKAL ACADEMY UDDAT SAIDEWALA / NA
Village :	Saidewala	Habitation :	Saidewala
Block:	Budhlada	District :	Mansa
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.02@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	02	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	57	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO3)	24	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO3)	10	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	2.40	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	0.97	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	57.98	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

- The results apply to the sample as received only.
- The sample will be destroyed after retention time unless otherwise specified specially.
- This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
- Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
- * Value not available or test not performed for this parameter.
- Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Komal Sharma

Ms. Komal Sharma
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Mansa

End of the Test Report